



CSI TESTING

14020 23rd Ave. N., Plymouth, MN 55447

(763) 383-9535 ■ Facsimile (763) 383-9546

Clean Environment Testing Since 1975

CERTIFICATE OF COMPLIANCE

**Colder Products
1001 Westgate Drive
St. Paul, Minnesota 55114**


January 20, 2011

Clean Area Description	Clean Area Class	Clean Area Status
Cleanroom	10,000 / ISO 7	Operational
Controlled Zone	100,000 / ISO 8	Operational
Staging Room	10,000 / ISO 7	At-Rest
Wipe Down Room	10,000 / ISO 7	At-Rest
Gown Room	10,000 / ISO 7	At-Rest
670 Machine	10,000 / ISO 7	At-Rest

Per the results of the particle count testing, the class is considered met if the measured particle concentration is within the limits specified per Federal Standard 209E, page 5, table 1, as determined by the statistical analysis of pages 14 and 15, paragraphs 5.4.2 through 5.4.2.6 and ISO 14644-1 (1999). Particle counts were sampled and reported in the cumulative mode for sizes 0.5 μm , 1.0 μm , and 5.0 μm at a flow rate of 1 cubic foot per minute.

CSI Testing, Inc. certifies that the above referenced clean area has been tested and meets or exceeds the stated class conditions in accordance with Federal Standard 209E and ISO 14644-1 (1999). CSI Testing, Inc. makes no other warranties, stated or implied, concerning the continued performance, operation or safety in use of the clean spaces listed above.

Submitted and Certified by:
CSI Testing, Inc.


Carl LaBella
President